

## **Soil & Water Conservation Society of Metro Halifax ('SWCSMH')**

*(a volunteer scientific stakeholder-group)*

310-4 Lakefront Road, Dartmouth, NS, Canada B2Y 3C4

Email: [limnos@chebucto.ns.ca](mailto:limnos@chebucto.ns.ca)

Tel: (902) 463-7777

Homepage: <http://www.chebucto.ns.ca/Science/SWCS/SWCS.html>

---

**Ref.:** WAB0016 (total= 3 pages)  
**To:** Chairman Dr. Wayne Stobo and Members,  
Halifax/Halifax County Watershed Advisory Board (WAB), HRM  
**From:** S. M. Mandaville (Professional Lake Manage.), Chairman & Exec. Director  
**Date:** June 26, 2000  
**Subject:** **TREATMENT LEVELS IN SEWAGE TREATMENT PLANTS**

---

I recall several discussions/inquiries about the 'level of treatment' in STPs during many of our Board meetings this year. Many times incorrect info has been offered by consultants and others. Here, I will point out to some published literature.

Please note the following:

- ◆ **There is nothing like 100% removal.**
  
- ◆ **Tertiary does not necessarily mean removal of all substances/pollutants. It depends upon what the STP is designed for.**
  
- ◆ **I am also concerned about 'claims' that LAND DISPOSAL is the answer. This is not a panacea either, and only certain substances are removed.**

- ◆ **There is also a concern how certain substances may reach shallow groundwater.**
  
- ◆ **Further concern is the lateral export of Phosphorus over time to the receiving LAKES (see our submission #WAB0015 dated June 23, 00 relating to phosphorus export from onsite septic systems!**

VIMP: Also please find enclosed two pages from established literature on removal efficiencies. In the case of Table WAB0016-3, you will have to adjust the effluent characteristics for various treatment systems by comparing the present raw wastewater characteristics to the raw waste in the first row. I had already provided these in our 66-page submission #WAB0002 during March, 00 but for convenience, they have been inserted here!

**References:**

Mandaville, S.M. 2000. Limnology- Eutrophication and Chemistry, Carrying Capacities, Loadings, Benthic Ecology, and Comparative Data. Soil & Water Conservation Society of Metro Halifax. xviii, Synopses 1, 2, 3, 13, and 14. 210p. {available at the DalTech Library and the Dalhousie Killam Science Library, Halifax}

Myers, E.P., and Harding, E.T. 1983. Ocean Disposal of Municipal Wastewater: Impacts on the Coastal Environment. 2 vols., MIT- Sea Grant College Program Report. MIT SG 83-33.

USEPA. 1976. Areawide assessment procedures manual. Vols I-III. Municipal Environ. Res. Lab., Cincinnati, Ohio. EPA-600/9-76-014.

USEPA. 1980. Clean Lakes Program Guidance Manual. Office of Water Regulations and Standards, Washington. EPA-440/5-81-003.

**Table WAB0016--1: Typical removals (in %) from Wastewater Treatment Systems (Myers and Harding, 1983)**

	<b>PRIMARY (Screening and grit removal, and Primary sedimentation)</b>	<b>SECONDARY (Biological oxidation (activated sludge), and Secondary sedimentation)</b>	<b>TERTIARY (Biological and chemical processes, carbon adsorption, filtration, ion exchange, and membrane separation processes)</b>
Suspended solids	50-60	85-90	>95
BOD <sub>5</sub>	35	85-90	>95
Nitrogen	0-20	10-30	80-95
Phosphorus	0-20	10-30	80-95
Heavy metals	0-40	15-65	50->95

**Table WAB0016--2: Typical Industrial Effluent Concentrations in mg/l (USEPA, 1980)**

<b>Parameter</b>	<b>Food</b>	<b>Textiles</b>	<b>Paper</b>	<b>Chemicals</b>	<b>Petroleum</b>	<b>Metal</b>
<u>BPT-1977</u>						
TSS	40	49	58	40	10	20
BOD <sub>5</sub>	29	22	39	30	15	38
Cl	565	25	135	---	---	---
TP	17	2	---	5	---	0.50
TN	50	2	---	20	70	62
<u>BAT-1983</u>						
TSS	10	8	23	13	5	5
BOD <sub>5</sub>	7	11	22	15	5	4
Cl	565	25	135	---	---	---
TP	1.2	2	---	3	---	0
TN	9	2	---	3	28	5

**Table WAB0016--3: Typical Treatment System Performance- STPs (USEPA, 1976)**

Description of System	Effluent Characteristics (mg/l)						
	BOD <sub>5</sub>	TSS	COD	TP	NH <sub>3</sub> -N	NO <sub>3</sub> -N	UOD
Raw Waste	210	230	400	11	20	0	406
Primary	130	100	250	9	20	0	286
Primary & Metal Salt Addition (FeCl <sub>3</sub> )	100	50	185	2	20	0	241
Primary & Trickling Filter	45	60	90	8	18	0	150
Primary, Trickling filter & Metal Salt (FeCl <sub>3</sub> )	25	30	50	2	18	0	120
Primary & Activated Sludge	20	20	45	7	17	0	107
Primary, Activated Sludge, Metal Salt (Alum)	15	15	35	2	17	0	100
Primary, Activated Sludge/ Nitrification	10	20	35	8	2	18	24
Primary, Activated Sludge, Nitrification, Denitrification	10	20	45	8	1	1	20
Primary Metal Salt Addition (Alum), Activated Sludge/Nitrification, Filtration	10	10	45	1	2	18	24
Preliminary, Two-Stage Lime, Filtration, Carbon Adsorption	5	5	25	1	20	0	99
Primary Metal Salt Addition (Alum), Activated Sludge, Nitrification, Denitrification, Polymer, Filtration	5	5	30	0.5	1	1	12
Primary Metal Salt Addition (Alum), Activated Sludge, Nitrification, Denitrification, Polymer, Filtration, Carbon Adsorption	3	5	10	0.5	1	1	12
Small-Flow Treatment Systems, i.e., Package Plants; Contact stabilization plant 0.1-1.0 mgd	20	20	45	---	17	0	107
Small-Flow Treatment Systems, i.e., Package Plants; Extended Aeration Plant 0.01-0.1 mgd;	20	20	45	---	2	0	107
Oxidation Ditch; 0.05-10. mgd (designed for nitrogen removal)	15	15	46	6	1	8	27
Land Application	---	---	---	---	---	---	---

UOD= Ultimate Oxygen Demand= (1.5 x BOD<sub>5</sub>) + (4.57 x NH<sub>3</sub>)